

Proposed Code Change State Form 41186R

RETURN TO: INDIANA DEPARTMENT OF HOMELAND SECURITY CODE SERVICES SECTION 302 W. Washington Street Room W246

Indianapolis, IN 46204

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY - Dashed line through material to be deleted, underline material to be added)

FOR OFFICE USE ONLY

Received 11/7/09

Code 65.7-09

Use second sheet for any material re-	quiring more space.	
Code Title		Edition
Indiana Residential Code		2009
Section number and title		Page
E4206.13.2		721
Proponent	Title	
Charlie Eldridge	Consultant	
Address		Phone
551 Grassy Ln., Indianapolis, IN 46217		(317) 370-3444
PROPOSED CODE CHANGE (Check One)		
☐ Change to read as follows ☐ Add to read as follows ☐ De	elete and substitute as follows	Delete without substitution
E4206.13.2 Permanently wired radiant heaters. Electric radiant heat mounting devices. Heaters shall not be installed over a pool or within inside walls of the pool and shall be mounted not less than 12 feet (approved.	in the area extending 5 feet (15	524 mm) horizontally from the
REASON AND FISCAL IMPACT		
Brought forward from the 2005 IRC and to match the 2008 NEC.		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		